DOCUMENTATION SHEET

Steel Spring Isolator Type SH1



General

Spring hanger units type SH.1 and SH.2 are designed to support pipelines and will stabilise installations. Placed at the right angle the spring hangers will stabilise the equipment in one plane.

Applications

- · Generator sets
- Emergency power supplies
- DC-AC converters
- · Industrial fans
- · Air-handling units
- Pumps

- · Air-conditioning machines
- Compressor packages
- · Electrical equipment
- Refrigerators
- Cooler units







Rubber Design vibration and noise control

| s | Cx, y [N/mm] | | | |
|-----------------|--------------|-------------------------|------------|---------------------|
| Туре | Cz [N/mm] | at preferential load | Fz max [N] | Fz preferential [N] |
| SH1-33 | 5,3 | Depending on rod length | 114 | 116 |
| SH1-55 | 10,8 | Depending on rod length | 274 | 238 |
| SH1-100 | 18,3 | Depending on rod length | 464 | 402 |
| SH1-143 | 25,9 | Depending on rod length | 658 | 570 |
| SH1-198 | 35,3 | Depending on rod length | 890 | 771 |
| SH1-242 | 43,8 | Depending on rod length | 1112 | 963 |
| SH1-298 | 52,5 | Depending on rod length | 1335 | 1156 |
| CHARACTERISTICS | | | | |

SH

Isolator selection

This described isolator selection is based on the vertical load of the isolators, if required seismic and 6 DOF calculations can be performed by our specialists.

- 1. Determine the total weight of the machine to be isolated, including work load
- 2. Determine the position of the combined centre of gravity in horizontal and vertical planes
- 3. Decide the number of isolators and the positions where the isolators are to be placed relative to the combined centre of gravity
- 4. Calculate the load per isolator
- 5. Select with the help of the preferential load in the table the suitable type of mounting

We recommend selection of the isolators be made with the load per isolator within + or - 10% of the preferential load. The static deflection of the isolator is calculated by dividing the load per isolator by the stiffness Cz given in the table for the selected isolator.



Rubber Design B.V.

Industrieweg 21 2995BE Heerjansdam The Netherlands Phone: +31 (0)78 677 87 78 Fax: +31 (0)78 677 10 38 Email: info@rubberdesign.nl Web: www.rubberdesign.nl

